




|   |  |
|---|--|
| Project Number: 277524                              | Tracking Code: 277524_Power Test Report_Rev_1 .doc |
| Requested by: Catie Eichhorn                        | Date: 12/20/2013                                   |
| Part #: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD |  |
| Part description: MPPT/MPPT                         | Technician: Kason He                               |
| Test Start: 11/12/2013                              | Test Completed: 12/16/2013                         |



# **SAMTEC POWER CHARACTERIZATION**

## **PART DESCRIPTION**

**MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD**

## CERTIFICATION

All instruments and measuring equipment were calibrated to National Institute for Standards and Technology (NIST) traceable standards according to ISO 10012-1 and ANSI/NCSL 2540-1, as applicable.

All contents contained herein are the property of Samtec. No portion of this report, in part or in full shall be reproduced without prior written approval of Samtec.

### SCOPE

1. Temperature Rise/Current Carrying Capacity
  - 1.1. To determine the amount of current the device under test (DUT) can safely carry over the operating temperature range of the DUT.
  - 1.2. Contact loading will also be addressed in this document which will determine how much current can be carried as the number of energized contacts is varied.
2. Current Cycling
  - 2.1. To determine the performance of the device under test (DUT) when subjected to the power-on/power-off cycling that heats and cools the DUT in normal everyday use.
  - 2.2. Contact loading will set to 100% throughout the test.


### APPLICABLE DOCUMENTS

Standards: EIA Publication 364-70 Temperature Rise  
EIA Publication 364-06 Contact Resistance  
EIA Publication 364-55 Current Cycling  
TLPM-032 Current Carrying Capacity  
TLPM-084 Current Cycling  
IEC 512-3 Electromechanical Components for Electronic Equipment: Basic Testing Procedures and Measuring Methods, Part 3: Current Carrying Capacity Tests

### TEST SAMPLES AND PREPARATION

- 1) All materials shall be manufactured in accordance with the applicable product specification.
- 2) All test samples shall be identified and encoded to maintain traceability throughout the test sequences.
- 3) After soldering, the parts to be used shall be cleaned according to TLWI-0001.
- 4) All samples shall be visually inspected and cleaned as necessary.
- 5) Any additional preparation shall be noted in the individual test sequences.
- 6) Solder Information: Lead Free
- 7) Re-Flow Time/Temp: See accompanying profile.
- 8) All products designed to operate mounted on a printed circuits board shall be tested mounted to test boards in accordance with EIA-364-70.

PREPARED TEST SAMPLE




- 9) The following loading configurations shall be tested for Temperature Rise/Current Carrying Capacity testing of two row connector systems:
- a. Two by One contact energized
  - b. Two by Two contacts energized adjacent to each other
  - c. Two by Three contacts energized adjacent to each other
  - d. Two by Four contacts energized adjacent to each other
  - e. All contacts energized

Test Condition as in 9.1 above


✦ Indicates energized contacts

✦ Indicates thermocouple monitored, energized contacts  
 ✦ Indicates thermocouple monitored, energized contacts



10) For Current Cycling, only 100 % loading will be tested.

**OVEN PROFILE (Soldering Parts to Test Boards)**



**FLOWCHARTS**

**Current Carrying Capacity**

Group 1  
MPPT-10-01-01-L-RA-SD  
MPPT-10-01-01-L-RA-SD  
1 Pins Powered  
Signal

| Step | Description                                    |
|------|--|
| 1.   | CCC (1)<br>Rows = 1<br>Number of Positions = 1 |

Group 2  
MPPT-10-01-01-L-RA-SD  
MPPT-10-01-01-L-RA-SD  
2 Pins Powered  
Signal

| Step | Description                                    |
|------|--|
| 1.   | CCC (1)<br>Rows = 1<br>Number of Positions = 2 |

Group 3  
MPPT-10-01-01-L-RA-SD  
MPPT-10-01-01-L-RA-SD  
3 Pins Powered  
Signal

| Step | Description                                    |
|------|--|
| 1.   | CCC (1)<br>Rows = 1<br>Number of Positions = 3 |

Group 4  
MPPT-10-01-01-L-RA-SD  
MPPT-10-01-01-L-RA-SD  
4 Pins Powered  
Signal

| Step | Description                                    |
|------|--|
| 1.   | CCC (1)<br>Rows = 1<br>Number of Positions = 4 |

Group 5  
MPPT-10-01-01-L-RA-SD  
MPPT-10-01-01-L-RA-SD  
10 Pins Powered  
Signal

| Step | Description                                     |
|------|---|
| 1.   | CCC (1)<br>Rows = 1<br>Number of Positions = 10 |

(1) CCC = EIA-364-70  
Method 2, Temperature Rise Versus Current Curve  
(TIN PLATING) - Tabulate calculated current at RT, 65°C, 75°C and 95°C after derating 20% and based on 105°C  
(GOLD PLATING) - Tabulate calculated current at RT, 85°C, 95°C and 115°C after derating 20% and based on 125°C

**Current Cycling**

Group 1  
MPPT-10-01-01-L-RA-SD  
MPPT-10-01-01-L-RA-SD  
8 Assemblies

| Step | Description       |
|------|-------------------|
| 1.   | Current Cycle (1) |

(1) Current Cycle = EIA 364-55  
Test Condition = B (125% Rated Current)  
Method = 4 (On: 45 Minutes, Off: 15 Minutes)  
Number of Cycles = 500



# POWER INTEGRITY TEST REPORT

277524

**INITIAL RELEASE**

## TEST PROCEDURES

|  |                       |                          |                       |
|--|-----------------------|--------------------------|-----------------------|
| <b>Part No.</b>  | MPPT-10-01-01-L-RA-SD | <b>Mating Part No.</b>   | MPPT-10-01-01-L-RA-SD |
| <b>Sample Size</b>   | 9                     | <b>Technician</b>        | Kason He              |
| <b>Start Date</b>  | 11/12/2013            | <b>Complete Date</b>     | 11/13/2013            |
| <b>Room Ambient</b>  | 22°C                  | <b>Relative Humidity</b> | 53%                   |
| <b>Equipment ID#: HZ-MO-01, HZ-PS-01, 277524-(039 - 047)</b> |                       |                          |                       |

### TEMPERATURE RISE (Current Carrying Capacity, CCC):

- 1) Thermocouples shall be calibrated in accordance with Samtec documents; TLWI 0003, Thermocouple Welding Procedure and TLWI 0005, Thermocouple Calibration
- 2) The thermocouples shall be placed at a location to sense the maximum temperature generated during testing.
- 3) Temperature stability shall be defined as the temperature at which three successive readings, 5 minutes apart, differ not more than 1° C (computer controlled data acquisition). This is the Temperature Rise that the Current Carrying Capacity and De-rating curves are based on.
- 4) The following loading configurations shall be tested (double for two row systems):
  - a. One contact energized only
  - b. Two contacts energized adjacent to each other
  - c. Three contacts energized adjacent to each other
  - d. Four contacts energized adjacent to each other
  - e. All contacts energized
- 5) The following loading configurations shall be tested for Temperature Rise/Current Carrying Capacity testing of two row connector systems:
  - a. Two by One contact energized
  - b. Two by Two contacts energized adjacent to each other
  - c. Two by Three contacts energized adjacent to each other
  - d. Two by Four contacts energized adjacent to each other
  - e. All contacts energized
- 6) Three samples shall be tested for each of the above configurations for a total of eighteen assemblies.
- 7) Temperature Rise measurements shall be made at 5 different current levels yielding temperature rises in the 10 to 70°C range.
- 8) The base curve for the Current Rating chart will be derived from the average (maximum) value of three test specimens in accordance with IEC 512-3, Test 5b.



**POWER INTEGRITY TEST  
REPORT**

**277524**

**INITIAL RELEASE**

|   |                              |                          |                              |
|---|------------------------------|--------------------------|------------------------------|
| <b>Part No.</b>   | <b>MPPT-10-01-01-L-RA-SD</b> | <b>Mating Part No.</b>   | <b>MPPT-10-01-01-L-RA-SD</b> |
| <b>Sample Size</b>  | <b>8</b>                     | <b>Technician</b>        | Kason He                     |
| <b>Start Date</b>   | 11/20/2013                   | <b>Complete Date</b>     | 12/16/2013                   |
| <b>Room Ambient</b>   | 22°C                         | <b>Relative Humidity</b> | 50%                          |
| <b>Equipment ID#: HZ-MO-06, HZ-PS-03, 277524(048 - 055)</b> |                              |                          |                              |

**CURRENT CYCLING**

1. Samples shall be prepared and tested as above (paragraph 14.5).
2. Current Cycling shall be performed in accordance with EIA-364-55, Test Condition
3. Testing shall be as follows:
  - 3.1. Test Current: 25.2 Amps (125% of 30°C Rating)
  - 3.2. "ON" Time: 45 Minutes
  - 3.3. "OFF" Time: 15 Minutes
  - 3.4. Number of Cycles: 500
  - 3.5. Measurements: 40 minutes into ON cycle
    - 3.5.1. Temperature
    - 3.5.2. Voltage Drop/Contact Resistance
4. Temperature vs. Number of Cycles and Voltage Drop vs. Number of Cycles shall be measured and recorded.



**TEST RESULTS**

**CURRENT CARRYING CAPACITY (CCC) RESULTS**

- There was no evidence of physical damage to the test samples as tested.
- The following is a summary of the observed data:

**Temperature Rise, CCC at a 20% de-rating**

- CCC for a 30°C Temperature Rise -----35.5 A per contact with 1 contacts (1 x 1) powered
- CCC for a 30°C Temperature Rise -----29.6 A per contact with 2 contacts (1 x 2) powered
- CCC for a 30°C Temperature Rise -----27.6 A per contact with 3 contacts (1 x 3) powered
- CCC for a 30°C Temperature Rise -----24.4 A per contact with 4 contacts (1 x 4) powered
- CCC for a 30°C Temperature Rise -----20.2 A per contact with 10 contacts (All) powered

**CURRENT CYCLING RESULTS**


**Test Condition: 500 Cycles, 45 minutes ON and 15 minutes OFF**

- Test Current -----25.2 Amps
- Contact Resistances, Measured 40 minutes into the FIRST and LAST ON cycle
  - Initial
    - Min ----- 0.23 mOhms
    - Max----- 0.42 mOhms
  - Final
    - Min ----- 0.22 mOhms
    - Max----- 0.40 mOhms
- Temperature Change, Measured 40 minutes into the FIRST and LAST ON cycle
  - Initial Temperature Change -----30.0°C
  - Final Temperature Change -----28.9°C

**TEST DATA**

**CONTACT RESISTANCE @ RATED CURRENT - DC Resistance (DCR)**

The following data represents the Voltage drop and Contact Resistance at Rated Current for the 100% energized samples:




**CONTACT RESISTANCE DATA  
ALL CONTACTS ENERGIZED  
(mΩ)**

| TEST CURRENT AMPS | 14.12 | 19.94 | 24.41 | 28.2 | 31.51 |
|-------------------|-------|-------|-------|------|-------|
| Min               | 0.22  | 0.22  | 0.23  | 0.23 | 0.24  |
| Max               | 0.4   | 0.41  | 0.42  | 0.42 | 0.43  |
| Avg               | 0.29  | 0.3   | 0.3   | 0.3  | 0.31  |

**TEST DATA**

**VOLTAGE DROP @ RATED CURRENT**

The following data represents the Voltage drop at Rated Current for the 100% energized samples:




**VOLTAGE DROP DATA  
ALL CONTACTS ENERGIZED  
(mV)**


| TEST CURRENT AMPS | 14.12 | 19.94 | 24.41 | 28.2  | 31.51 |
|-------------------|-------|-------|-------|-------|-------|
| Min               | 3.07  | 4.42  | 5.53  | 6.52  | 7.43  |
| Max               | 5.64  | 8.17  | 10.17 | 11.96 | 13.61 |
| Avg               | 4.22  | 6.09  | 7.57  | 8.88  | 10.09 |

**CURRENT CARRYING CAPACITY DATA**

277524  
1(1X1) Contacts in Linear series  
Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD



277524  
1(1X1) Contacts in Linear series  
Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD





# POWER INTEGRITY TEST REPORT

277524

INITIAL RELEASE

## TEMPERATURE RISE DATA TWO CONTACT ENERGIZED (Degrees Celsius above ambient)

| TEST CURRENT AMPS | 24.4 | 34.55 | 42.32 | 48.88 | 54.65 |
|-------------------|------|-------|-------|-------|-------|
| Sample 1          | 9.3  | 17.8  | 25.9  | 33.9  | 44.7  |
| Sample 2          | 10.2 | 19.6  | 28.9  | 38.1  | 47.1  |
| Sample 3          | 9.4  | 18    | 26.3  | 34.4  | 45.6  |
| Min               | 9.3  | 17.8  | 25.9  | 33.9  | 44.7  |
| Max               | 10.2 | 19.6  | 28.9  | 38.1  | 47.1  |
| Avg               | 9.63 | 18.47 | 27.03 | 35.47 | 45.8  |


Single Row Configuration

✦ Indicates energized contacts


✦ Indicates thermocouple monitored, energized contacts

|   |  |  |  |
|---|--|--|--|
| ✦ |  |  |  |
|---|--|--|--|

**277524**  
**2(1X2) Contacts in Linear series**  
**Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD**



**277524**  
**2(1X2) Contacts in Linear series**  
**Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD**





**POWER INTEGRITY TEST  
REPORT**

**277524**  
**INITIAL RELEASE**

**TEMPERATURE RISE DATA  
FOUR CONTACTS ENERGIZED  
(Degrees Celsius above ambient)**

| TEST CURRENT<br>AMPS | 20.63 | 29.16 | 35.75 | 41.28 | 46.16 |
|----------------------|-------|-------|-------|-------|-------|
| Sample 4             | 9.5   | 18.3  | 26.9  | 35.5  | 44    |
| Sample 5             | 10.1  | 19.7  | 29.3  | 38.8  | 48.3  |
| Sample 6             | 9.8   | 19    | 28.1  | 37.2  | 46.4  |
| Min                  | 9.5   | 18.3  | 26.9  | 35.5  | 44    |
| Max                  | 10.1  | 19.7  | 29.3  | 38.8  | 48.3  |
| Avg                  | 9.8   | 19    | 28.1  | 37.17 | 46.23 |


✦ Indicates energized contacts

✦ Indicates thermocouple monitored, energized contacts


|   |   |  |  |
|---|---|--|--|
| ✦ | ✦ |  |  |
|---|---|--|--|

277524  
3(1X3) Contacts in Linear series  
Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD

Current Rating per Contact (30 Deg. Rise, 20% Derated) = 27.6Amps



277524  
3(1X3) Contacts in Linear series  
Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD





# POWER INTEGRITY TEST REPORT

277524

INITIAL RELEASE

## TEMPERATURE RISE DATA SIX CONTACTS ENERGIZED (Degrees Celsius above ambient)

| TEST CURRENT<br>AMPS | 18.19 | 25.7  | 31.5  | 36.38 | 40.69 |
|----------------------|-------|-------|-------|-------|-------|
| Sample 7             | 9.4   | 17.4  | 25.2  | 32.9  | 40.5  |
| Sample 8             | 9.6   | 18.2  | 26.5  | 34.7  | 42.7  |
| Sample 9             | 9.1   | 17.1  | 24.9  | 32.3  | 39.6  |
| Min                  | 9.1   | 17.1  | 24.9  | 32.3  | 39.6  |
| Max                  | 9.6   | 18.2  | 26.5  | 34.7  | 42.7  |
| Avg                  | 9.37  | 17.57 | 25.53 | 33.3  | 40.93 |


✦ Indicates energized contacts

✦ Indicates thermocouple monitored, energized contacts


|   |   |   |  |
|---|---|---|--|
| ✦ | ✦ | ✦ |  |
|---|---|---|--|

**277524**  
**4(1X4) Contacts in Linear series**  
**Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD**

*Current Rating per Contact (30 Deg. Rise, 20% Derated) =24.4 Amps*



**277524**  
**4(1X4) Contacts in Linear series**  
**Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD**





**POWER INTEGRITY TEST  
REPORT**

**277524**  
**INITIAL RELEASE**

**TEMPERATURE RISE DATA  
EIGHT CONTACTS ENERGIZED  
(Degrees Celsius above ambient)**

| TEST CURRENT<br>AMPS | 16.45 | 23.27 | 28.5  | 32.92 | 36.82 |
|----------------------|-------|-------|-------|-------|-------|
| Sample 10            | 10    | 18.9  | 28.5  | 37.9  | 46.3  |
| Sample 11            | 10.3  | 20    | 30.1  | 38.9  | 47.9  |
| Sample 12            | 9.7   | 18.1  | 28.2  | 37.1  | 45.9  |
| Min                  | 9.7   | 18.1  | 28.2  | 37.1  | 45.9  |
| Max                  | 10.3  | 20    | 30.1  | 38.9  | 47.9  |
| Avg                  | 10    | 19    | 28.93 | 37.97 | 46.7  |


✦ Indicates energized contacts

✦ Indicates thermocouple monitored, energized contacts




**277524**  
**10(All) Contacts in Linear series**  
**Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD**

*Current Rating per Contact (30 Deg. Rise, 20% Derated) = 20.2Amps*




**277524**  
**10(All) Contacts in Linear series**  
**Part Numbers: MPPT-10-01-01-L-RA-SD/MPPT-10-01-01-L-RA-SD**




**TEMPERATURE RISE DATA  
ALL CONTACTS ENERGIZED  
(Degrees Celsius above ambient)**

| TEST CURRENT AMPS | 14.12 | 19.94 | 24.41 | 28.2  | 31.51 |
|-------------------|-------|-------|-------|-------|-------|
| Sample 13         | 9.6   | 18.6  | 27    | 35.5  | 43.6  |
| Sample 14         | 10.3  | 20.2  | 29.7  | 39.1  | 48.3  |
| Sample 15         | 10    | 19.2  | 28.1  | 37.1  | 46.1  |
| Min               | 9.6   | 18.6  | 27    | 35.5  | 43.6  |
| Max               | 10.3  | 20.2  | 29.7  | 39.1  | 48.3  |
| Avg               | 9.97  | 19.33 | 28.27 | 37.23 | 46    |


- ✦ Indicates energized contacts
- ✦ Indicates thermocouple monitored, energized contacts






**TEMPERATURE RISE DATA  
ALL CONTACTS ENERGIZED  
(Degrees Celsius above ambient)**

|            | <b>INITIAL</b> | <b>50 CYCLES</b> | <b>100 CYCLES</b> | <b>200 CYCLES</b> | <b>500 CYCLES</b> |
|------------|----------------|------------------|-------------------|-------------------|-------------------|
| <b>Min</b> | 28.9           | 28.3             | 27.9              | 28.1              | 28.5              |
| <b>Max</b> | 31.2           | 30.3             | 30.1              | 30.1              | 30.1              |
| <b>Avg</b> | 30             | 29.1             | 28.9              | 28.8              | 28.9              |



**CONTACT RESISTANCE DATA  
ALL CONTACTS ENERGIZED  
(mΩ)**

|            | INITIAL | 50 CYCLES | 100 CYCLES | 200 CYCLES | 500 CYCLES |
|------------|---------|-----------|------------|------------|------------|
| <b>Min</b> | 0.23    | 0.22      | 0.22       | 0.22       | 0.22       |
| <b>Max</b> | 0.42    | 0.4       | 0.4        | 0.4        | 0.4        |
| <b>Avg</b> | 0.32    | 0.3       | 0.3        | 0.3        | 0.29       |



**VOLTAGE DROP DATA  
ALL CONTACTS ENERGIZED  
(MV)**

|            | INITIAL | 50 CYCLES | 100 CYCLES | 200 CYCLES | 500 CYCLES |
|------------|---------|-----------|------------|------------|------------|
| <b>Min</b> | 5.78    | 5.62      | 5.6        | 5.57       | 5.53       |
| <b>Max</b> | 10.61   | 10.21     | 10.18      | 10.13      | 10.06      |
| <b>Avg</b> | 7.96    | 7.58      | 7.53       | 7.47       | 7.4        |



**POWER INTEGRITY TEST  
REPORT**

**277524**

**INITIAL RELEASE**

**EQUIPMENT AND CALIBRATION SCHEDULES**

**Equipment #:** HZ-MO-06

**Description:** Multimeter /Data Acquisition System

**Manufacturer:** Keithley

**Model:** 2750

**Serial #:** 1310732C

**Accuracy:** See Manual

... Last Cal: 01/30/2013, Next Cal: 01/29/2014

**Equipment #:** HZ-PS-03

**Description:** 30 Amp Power Supply

**Manufacturer:** Agilent

**Model:** 6033A

**Serial #:** 3329A-07330

**Accuracy:** See Manual

... Last Cal: 02/02/2013, Next Cal: 02/01/2013

**Equipment #:** HZ-MO-01

**Description:** Multimeter/Switch System

**Manufacturer:** Keithley

**Model:** 2700

**Serial #:** 1199807

**Accuracy:** See Manual

... Last Cal: 07/02/2013, Next Cal: 07/01/2014

**Equipment #:** HZ-PS-01

**Description:** 120 Amp Power Supply

**Manufacturer:** Agilent

**Model:** 6031A

**Serial #:** MY41000982

**Accuracy:** See Manual

... Last Cal: 07/02/2013, Next Cal: 07/01/2014